

DOCKER SMITH PTY LIMITED

ABN 17 001 705 237

CONSULTING STRUCTURAL & CIVIL ENGINEERS

7/141 PENSHURST STREET, WILLOUGHBY NSW 2068 TELEPHONE 9411 3211

Email: docksmith@bigpond.com



23090/003

18 June, 2024

Natural Lighting Products
15/2-8 South Street
RYDALMERE NSW 2116

Attention: Mr D. Moore

Dear Sir,

re: Infiniti Edge Skylights

We have reviewed your information sheets showing your range of fixed Infiniti Edge skylights and we have checked the glass for compliance with the Code AS 1288 - 2021, Glass in Buildings – Selection and Installation.

We find that units type:-

- ◆ FHM66, FHM68, FHM69, FHM88, FHM99,
- ◆ FHM612, FHM812, FHM1212.

All glazed with 4mm toughened outer pane with Sun Guard protective filter, 18mm air filled cavity and 6.38 laminated toughened inner pane comply with the requirements of the above-mentioned Code.

The units have been tested and passed for resistance to concentrated loads and resistance to wind pressure for Non-cyclonic regions by a registered NATA Laboratory.

Yours faithfully,

DOCKER SMITH PTY LIMITED

A handwritten signature in blue ink, appearing to read 'Richard Binns'.

R. T. Binns