

DOCKER SMITH PTY LIMITED

ABN 17 001 705 237

CONSULTING STRUCTURAL & CIVIL ENGINEERS

7/141 PENSHURST STREET, WILLOUGHBY NSW 2068 TELEPHONE 9411 3211

Email: docksmith@bigpond.com



23090/001

8 March, 2024

Natural Lighting Products
15/2-8 South Street
RYDALMERE NSW 2116

Attention: Mr D. Moore

Dear Sir,

re: Keylite Fixed Skylights

We have reviewed your information sheets showing your range of fixed skylights and we have checked the glass for compliance with the Code AS 1288 - 2021, Glass in Buildings – Selection and Installation.

We find that units type:-

- ◆ RWF 01S, RWF 02, RWF 01C, RWF 01F, RWF 04, RWF 05, RWF 06 and RWF 08S
- ◆ RWM 01S, RWM 02, RWM 01C, RWM 01F, RWM 04, RWM 05, RWM 06 and RWM 08S
- ◆ RWE 01S, RWE 02, RWE 01C, RWE 01F, RWE 04, RWE 05, RWE 06 and RWE 08S

All glazed with 4mm toughened outer pane with Sun Guard protective filter, 18mm Argon gas filled cavity and 6.38 laminated inner pane comply with the requirements of the above-mentioned Code.

The units have been tested and passed for resistance to concentrated loads and resistance to wind pressure for Non-cyclonic regions by a registered NATA Laboratory.

Yours faithfully,

DOCKER SMITH PTY LIMITED

A handwritten signature in blue ink that reads "Richard Binns".

R. T. Binns

DIRECTOR: R.T. Binns MIEAust CPEng NER APEC Engineer IntPE(Aus)
Member Structural and Civil College MN 826857
Professional Engineer Registration PRE0001278